



ADDENDUM #2

October 11, 2018

1. Question: A 48" RCP pipe is too large for a standard type C single grate catch basin
Answer: Please substitute a double catch basin in lieu of.
2. The Town has 800 linear feet of 18" plastic corrugated drainage pipe and 40 linear feet of 48" plastic corrugated drainage pipe (See Pictures) that shall be used for this project. The contractor awarded this project must coordinate pick-up/delivery of this pipe directly with First Selectman Rick Ives.



End of Addendum #2